

### **IECEx Certificate** of Conformity

### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx BVS 17.0091X	issue No.:0	Certificate history:
Status:	Current		
Date of Issue:	2017-12-01	Page 1 of 3	
Applicant:	RECKMANN GMBH Werkzeugstr. 19 - 23 58093 Hagen Germany	2	
Equipment: Optional accessory:	Temperature sensors	, details See general product infor	mation
Type of Protection:	Equipment protection Level (EPL) Ga	n by intrinsic safety "i", Equipment	with Equipment Protection
Marking:	See Annex		
Approved for issue on a Certification Body:	behalf of the IECEx	Jörg Koch	
Position:		Head of Certification Body	
Signature: (for printed version)			
Date:		11.12.17	
<ol><li>This certificate is not</li></ol>	schedule may only be repro transferable and remains enticity of this certificate m	Just	FCEx Website

Certificate issued by:

**DEKRA EXAM GmbH** Dinnendahlstrasse 9 44809 Bochum Germany





# IECEx Certificate of Conformity

Certificate No.:

IECEx BVS 17.0091X

Date of Issue:

2017-12-01

Issue No.: 0

Page 2 of 3

Manufacturer:

RECKMANN GMBH Werkzeugstr. 19 - 23 58093 Hagen Germany

#### Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-11: 2011

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 6.0

IEC 60079-26 : 2014-

Explosive atmospheres - Part 26: Equipment with Equipment Protection Level (EPL) Ga

10

Edition: 3.0

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/BVS/ExTR17.0086/00

Quality Assessment Report:

DE/BVS/QAR14.0005/03



# IECEx Certificate of Conformity

		2000	
Certificate No.:	IECEx BVS	17.0091X	
Date of Issue:	2017-12-01		Issue No.: 0
			Page 3 of 3
		Schedule	
EQUIPMENT: Equipment and systems	covered by this certif	ficate are as follows:	
ype code			
See Annex			
Description			
ength of up to 8000 mm Jp to 2 sensor elements espectively the cable se	sistance elements on are installed in the ensors, each in 2-, 3- s respectively the ma	or thermocouples) are platemperature sensors res - or 4-wire-technology. Teasuring inserts respecti	aced on the tip of a metal tube with a spectively the measuring inserts ively the cable sensors have to be
connected only to one in	trinsically sale circu	и.	
Ratings			
See Annex			
SPECIFIC CONDITION	S OF USE: YES as s	hown below:	
See Annex			
. a 4/3			
Jacks and			
기유지 : 세크			
생활되는하다하네			





Certificate No.: IECEx BVS 17.0091X

Annex Page 1 of 13

#### Marking:

Temperature sensors type	Marking
BWR15-***-*	Ex ia I Mb
WR15-B***-*-*, WR15-C***-*-*, WR15-D***-*-*, WR15-E***-*-*, WR15-F***-*-*, WR15-G***-*-*, WR15-H***-*-*, WR15-J***-*-*, TR15-B***-*-*, TR15-C***-*-*, TR15-E***-*-*, TR15-G***-*-*, TR15-H***-*-*, TR15-J***-*-*	Ex ia IIC T1 T6 Ga/Gb Ex ia IIIC T135°C Da/Db
WR15-K***-*-*, WR15-L***-*-*, WR15-CX***-*-*, WR15-EX***-*-*, TR15-K***-*-*, TR15-CX***-*-*, TR15-EX***-*-*, WR14-J-****-*, TR14-J-***-*, WR14-J-***-*, TR14-J-***-*, WR14-X-***-*, TR14-X-***-*,	Ex ia IIC T1 T6 Gb Ex ia IIIC T135°C Db
WR14-O*-****, TR14-O*-****, WR14-P*-****, TR14-P*-****, WR14-M*-***, TR14-M*-***, RKW-8-*-****, RKW-9-*-****	Ex ia IIC T1 T6 Ga Ex ia IIIC T135°C Da





Certificate No.: IECEx BVS 17.0091X

Annex Page 2 of 13

#### Type code:

Resistance temperature detector	BWR15	_*	*	*	*	-*	-*
Protection fitting type			T.	N. S. Marketter			
Model 2 with coupling nut		В					
Model 8 (2GoH)		С					
Model 2G		D					
Number of sensors		a shankilali	gyi				
Single			1				
Double			2				
Sensor					A KINE	Water State	
PT100				PT100			
PT1000				PT1000			
Type R14 measuring insert					STATE OF		
R144					D		
Measuring insert diameter			1, 1,			i bung	
3.00 mm						300	
6.00 mm						600	
8.00 mm						800	
Cable connection		N. W. P.	1777		SULLA		
Cable gland							Х
M12 built-in plug VA							Α
M12 built-in socket VA							В





Certificate No.: IECEx BVS 17.0091X

Annex Page 3 of 13

Resistance temperature detector	WR15	_*	*	*	*	-*	-*
Mineral insulated thermocouple	TR15	_*	*	*	w	_*	_*
Protection fitting type			191				
Model 2		В			Ť.		
Model 8 (2GoH)		С	T				
Model 2G		D					
Model 2F		E	125				
Model 3		F					
Model 3GoH		G					
Model 3G		H					
Model 3F		J					
Model 4 without protection tube		K					
Model 4F without protection tube		L					
Model 2GoH without protection tube		СХ	$\top$				
Model 2F without protection tube		EX					
Number of sensors	ar base st	6 7 4 5	4			To may	130
Single			1		T		
Double			2				
Sensor		Marine A		VEHICLE AT	PIKO, I	i siy	
PT100	WR15		Т	PT100			Т
PT1000	WR15			PT1000			
Ni100	WR15			Ni100			
Cu-CuNi type T	TR15			T			
Fe-CuNi type J	TR15			J			
NiCr-CuNi type E	TR15			E			
NiCr-Ni type K	TR15			K			
NiCrSi-NiSi type N	TR15			N			
Pt13%Rh-Pt type R	TR15			R			
Pt10%Rh-Pt type S	TR15			S			
Measuring insert type	K DE COMPLETE				n in		A
R144					D		
R149					Q		
Measuring insert diameter	e jilat, biki w	ALL SELECTION		in a least single	ryen.		2 1
3.00 mm						300	
6.00 mm						600	
8.00 mm						800	
Cable connection	iyor aşı endi	the second	2011				1
Cable gland							X
M12 built-in plug							Α
M12 built-in socket							В





Certificate No.: IECEx BVS 17.0091X

Annex Page 4 of 13

Resistance temperature detector	WR14	_*	_*	*	*	*	_*
Mineral insulated thermocouple	TR14	_*	-*	*	*	*	-*
Measuring insert type					\$ 1.5Va		
Model B		J					
without connection head		Х					
Model R144			D				
Model R149 free-ended			Q				
Measuring insert diameter		5.35.4					N.
3.00 mm				300			
6.00 mm				600			
8.00 mm				800			
Number of sensors					/4 = "N		Į į
Single					1		
Double					2		
Sensor		All Mary					
PT100	WR14					PT100	
PT1000	WR14					PT1000	
Ni100	WR14					Ni100	
Cu-CuNi type T	TR14	58				Т	
Fe-CuNi type J	TR14					J	
NiCr-CuNi type E	TR14					E	
NiCr-Ni type K	TR14			77.		K	
NiCrSi-NiSi type N	TR14					N	
Pt13%Rh-Pt type R	TR14					R	
Pt10%Rh-Pt type S	TR14					S	
Cable connection				1 1 10 11	15 30	to Fore Spire	1.77
without (for ME) / cable gland							X
M12 built-in plug							Α
M12 built-in socket							В





Certificate No.: IECEx BVS 17.0091X

Annex Page 5 of 13

Resistance temperature detector	WR14	_*	*	_*	*	*	*
Mineral insulated thermocouple	TR14	_*	*	-*	*	*	*
Measuring insert type	A N. D. L.	104	II FOLKO	Maria,			
Model D		0					Π
Model DST (D with plug connector)		Р					
Measuring insert diameter		1, (Talm	nuelly in	135	to be distant		
1.50 mm (only single sensor)			150				Τ
2.00 mm (only single sensor)			200				
3.00 mm			300				
6.00 mm			600				
8.00 mm			800				
Number of sensors					herioe iv,	N ORDIN	
Single		T		1			Τ
Double				2			
Sensor			3 W.				O'T
PT100	WR14				PT100		
PT1000	WR14				PT1000		
Ni100	WR14				Ni100		
Cu-CuNi type T	TR14				Т		
Fe-CuNi type J	TR14				J		
NiCr-CuNi type E	TR14				E		
NiCr-Ni type K	TR14				K		
NiCrSi-NiSi type N	TR14				N		
Pt13%Rh-Pt type R	TR14				R		
Pt10%Rh-Pt type S	TR14				S		
Connection cables		yine, n				I WAR	
PVC/PVC						Α	
PVC/shielding/PVC						В	
Glass silk/silicone						С	
Glass silk/silicone/glass silk/shielding						D	
Silicone/silicone/FEP						E	
Siliconeon/silicone/shielding/FEP						F	
Cable connection		77		ŊT,	The second		
Free-ended cables							Х
Mini compensation plug connector							Α
Lemo plug connector							Е
M12 / M8 plug connector							C





Certificate No.:

**IECEx BVS 17.0091X** 

Annex Page 6 of 13

Resistance temperature detector	WR14	_*	*	-*	*	*
Mineral insulated thermocouple	TR14	_*	*	_*	*	*
Measuring insert type		XII ZIEL		gi y		
Model L		М				
Measuring insert diameter	Maria Maria	1.00		57		1
1.50 mm (only single sensor)			150			
2.00 mm (only single sensor)			200			
3.00 mm			300			
6.00 mm (only with Lemo plug connector)			600			
8.00 mm (only with Lemo plug connector)			800			
Number of sensors		ev Sanny	STORE.	Y GAN		di ya
Single				1		
Double				2		
Sensor		u Tèu,				NE K
PT100	WR14				PT100	
PT1000	WR14				PT1000	
Ni100	WR14				Ni100	
Cu-CuNi type T	TR14				Т	
Fe-CuNi type J	TR14				J	
NiCr-CuNi type E	TR14				E	
NiCr-Ni type K	TR14				K	
NiCrSi-NiSi type N	TR14				N	
Pt13%Rh-Pt type R	TR14				R	
Pt10%Rh-Pt type S	TR14				S	
Cable connection				1970	Tributi boj l	
Mini compensation plug connector						F
Lemo plug connector						E





Certificate No.:

**IECEx BVS 17.0091X** 

Annex Page 7 of 13

Resistance temperature detector	RKW	-*	-*	-*	*	*	*
Cable sensor type		0 1 1		74.5		11113)	in c
without pipe clip		8					
with pipe clip		9					
Sensor diameter		Se militar	A LOSINE			7, 12	
3.00 mm			300				
4.00 mm			400				
6.00 mm			600				
8.00 mm			800				
Number of sensors		THE REAL PROPERTY.	(1) (1)(4)				7,0
Single				1			
Double				2			
Sensor			A CONTRACT	V. O.		4	0
PT100					PT100		
PT1000					PT1000		
Ni100					Ni100		
Connection cables	100	d open					93
PVC/PVC						Α	
PVC/shielding/PVC						В	
Glass silk/silicone						С	
Glass silk/silicone/glass silk/shielding						D	
Silicone/silicone/FEP						E	
Silicone/silicone/shielding/FEP						F	
Cable connection							111
Free-ended cables							X
Lemo plug connectors							В
M12 / M8 plug connectors							С





Certificate No.:

IECEx BVS 17.0091X

Annex Page 8 of 13

#### Ratings

The temperature sensors respectively the measuring inserts respectively the cable sensors have to be connected only to one intrinsically safe circuit independ of the number of wires.

Minimum permissible process temperature for all sensors: -40 °C

1 Temperature sensor type BWR15-\*\*\*\*-\*-, Ex ia I Mb (mining)

Maximum input voltage	Ui	DC	15	V
Maximum input current	l <sub>i</sub>		100	mA
Maximum input power	Pi	see table		
Maximum internal capacitance	Ci		neglig	gible
Maximum internal inductance	Li		neglig	gible

Permissible process temperature in °C depends on Pi and the measuring insert diameter

type	20 mW	50 mW	250 mW	500 mW	750 mW
BWR15-***-300-*	146	140	104	58	12
BWR15-***-600-*	147	144	123	97	71
BWR15-***-800-*	147	144	123	97	71

Ambient temperature range of the connection head: -40 °C up to +80 °C

2 Temperature sensor type WR15-B\*\*\*-\*-\*, WR15-C\*\*\*-\*-\*, WR15-D\*\*\*-\*-\*, WR15-E\*\*\*-\*-\*, WR15-F\*\*-\*-\*, WR15-G\*\*\*-\*-\*, WR15-H\*\*\*-\*-\*, WR15-J\*\*\*-\*-\*, TR15-B\*\*\*-\*-\*, TR15-C\*\*\*-\*-\*, TR15-D\*\*\*-\*-\*, TR15-E\*\*\*-\*-\*, TR15-F\*\*-\*-\*, TR15-G\*\*\*-\*-\*, TR15-H\*\*\*-\*-\*, TR15-J\*\*\*-\*-\*

Ex ia IIC T1 ... T6 Ga/Gb (with partition wall)

Maximum input voltage	Ui	DC	30	V
Maximum input current	l <sub>i</sub> '		100	mΑ
Maximum input power	P <sub>i</sub>		see table	
Maximum internal capacitance	C <sub>i</sub>		neglig	jible
Maximum internal inductance	Li		neglig	jible

Permissible process temperature in °C depends on P<sub>i</sub> and the temperature class.

For types WR15 and measuring insert diameter 3 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	438	435	417	394	371
T2	288	285	267	244	221
Т3	193	190	172	149	126
T4	128	125	107	84	61
T5	93	90	72	49	26
T6	78	75	57	34	11

For types WR15 and measuring insert diameter 6 mm and 8 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	439	437	427	414	401
T2	289	287	277	264	251
Т3	194	192	182	169	156
T4	129	127	117	104	91
T5	94	92	82	69	56
Т6	79	77	67	54	41





Certificate No.: IECEx BVS 17.0091X

Annex Page 9 of 13

For types TR15 and measuring insert diameter 3 mm, 6 mm and 8 mm:

temperature class	750 mW
T1	435
T2	285
Т3	190
T4	125
T5	90
T6	75

Ambient temperature range of the connection head: -40 °C up to +80 °C for T5 ... T6 -40 °C up to +100 °C for T1 ... T4

Note: If replacing the cable gland with a built-in M12 plug connector,

the ambient temperature range is reduced to -40 °C to +80 °C for T1...T6.

#### Ex ia IIIC T135°C Da/Db (with partition wall)

Maximum input voltage	Ui	DC	30	V
Maximum input current	l <sub>i</sub>		100	mA
Maximum input power	P <sub>i</sub>	P <sub>i</sub> s		able
Maximum internal capacitance	Ci		neglig	gible
Maximum internal inductance	Li		neglig	gible

Permissible ambient-/process temperature range in °C depend on Pi

Pi	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

Note: If replacing the cable gland with a built-in M12 plug connector, the ambient temperature range is reduced to -40 °C to +80 °C.

3 Temperature sensor type WR15-K\*\*\*-\*-\*, WR15-L\*\*\*-\*-\*, WR15-CX\*\*\*-\*-\*, WR15-EX\*\*\*-\*-\*, TR15-K\*\*\*-\*-\*, TR15-L\*\*\*-\*-\*, TR15-CX\*\*\*-\*-\*, TR15-EX\*\*\*-\*-\*, and measuring insert Typ WR14-J-\*\*\*\*-\*, TR14-J-\*\*\*\*-\*, WR14-X-\*\*\*\*-\*, TR14-X-\*\*\*\*-\*

#### Ex ia IIC T1 ... T6 Gb

Maximum input voltage	U,	DC	30	V
Maximum input current	ĵ,		100	mA
Maximum input power	Pi	P <sub>i</sub>		able
Maximum internal capacitance	C		neglig	gible
Maximum internal inductance	$L_{i}$		neglig	gible

Permissible process temperature in °C depends on P<sub>i</sub> and the temperature class.

For types WR15 and measuring insert diameter 3 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	436	430	394	348	302
T2	286	280	244	198	152
T3	191	185	149	103	57
T4	126	120	84	38	/
T5	91	85	49	3	1
T6	76	70	34	1	1





**Certificate No.:** 

**IECEx BVS 17.0091X** 

Annex Page 10 of 13

For types WR15 and measuring insert diameter 6 mm and 8 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	437	434	413	387	361
T2	287	284	263	237	211
Т3	192	189	168	142	116
T4	127	124	103	77	51
T5	92	89	68	42	16
T6	77	74	53	27	1

For types TR15 and measuring insert diameter 3 mm, 6 mm and 8 mm:

temperature class	750 mW
T1	430
T2	280
T3	185
T4	120
T5	85
T6	70

Ambient temperature range of the connection head: -40 °C up to +80 °C for T5 ... T6 -40 °C up to +100 °C for T1 ... T4

Note: If replacing the cable gland with a built-in M12 plug connector, the ambient temperature range is reduced to -40 °C to +80 °C for T1...T6.

#### Ex ia IIIC T135°C Db

Maximum input voltage	U <sub>i</sub>	DC	30	V
Maximum input current	li '	500034	100	mA
Maximum input power	P <sub>i</sub> ,		see ta	able
Maximum internal capacitance	C		neglig	ible
Maximum internal inductance	L <sub>i</sub>		neglig	1.0000000000000000000000000000000000000

Permissible ambient-/process temperature range in °C depend on Pi

Pi	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

Note: If replacing the cable gland with a built-in M12 plug connector, the ambient temperature range is reduced to -40 °C to +80 °C.

4 Temperature sensor type WR14-O\*-\*\*\*\*, TR14-O\*-\*\*\*\*, WR14-P\*-\*\*\*\*, TR14-P\*-\*\*\*\*, WR14-M\*-\*\*\*, TR14-M\*-\*\*\*

#### Ex ia IIC T1 ... T6 Ga

Maximum input voltage	Ui	DC	30	V	
Maximum input current	l <sub>i</sub>		100	mA	
Maximum input power	power P <sub>i</sub>		see table		
For type WR14-M*-***, TR14-M*-***:					
Maximum internal capacitance	Ci		neglig	ible	
Maximum internal inductance	L'		(A) (A) (A) (A) (A) (A) (A) (A)	negligible	
For type WR14-O*-****, TR14-O*-****, WR14-P*-***	*, TR14-P*-****	(cable length	th max. 50 r	n)	
Maximum internal capacitance	C		0.2 nF	1. P. S.	
Maximum internal inductance	Li		1 µH/ı	m	



### IECEx Certificate of Conformity



Certificate No.: IECEx BVS 17.0091X

Annex Page 11 of 13

Permissible process temperature in °C depends on P<sub>I</sub> and the temperature class.

For types WR14 and measuring insert diameter 1.5 mm and 2 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	434	426	369	300	229
T2	284	276	219	150	79
Т3	189	181	124	55	1
T4	124	116	59	/	1
T5	89	81	24	1	/
Т6	74	66	9	1	1

For types WR14 and measuring insert diameter 3 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	436	430	394	348	302
T2	286	280	244	198	152
T3	191	185	149	103	57
T4	126	120	84	38	1
T5	91	85	49	3	1
Т6	76	70	34	1	1

For types WR14 and measuring insert diameter 6 mm and 8 mm:

5.5					36
temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	437	434	413	387	361
T2	287	284	263	237	211
Т3	192	189	168	142	116
T4	127	124	103	77	51
T5	92	89	68	42	16
T6	77	74	53	27	1

For types TR14 and measuring insert diameter 1.5 mm, 2 mm, 3 mm, 6 mm and 8 mm:

temperature class	750 mW	
T1	430	
T2	280	
Т3	185	
T4	120	
T5	85	
T6	70	

Ambient temperature range of the sleeve, connection cable and plug connector for type WR14-O\*-\*\*\*\*, TR14-O\*-\*\*\*\*, WR14-P\*-\*\*\*\*; TR14-P\*-\*\*\*\*;

-40 °C up to +75 °C for T5 ... T6

-40 °C up to +100 °C for T1 ... T4

Ambient temperature range of the plug connector for type WR14-M\*-\*\*\*, TR14-M\*-\*\*\*:

-40 °C up to +80 °C for T5 ... T6

-40 °C up to +100 °C for T1 ... T4





Certificate No.: IECEx BVS 17.0091X

Annex

Page 12 of 13

#### Ex ia IIIC T135°C Da

Maximum input voltage	Ui	DC	30	V
Maximum input current	l <sub>i</sub>		100	mΑ
Maximum input power	Pi		see ta	able
For type WR14-M*-***, TR14-M*-***:				
Maximum internal capacitance	Ci		negligible	
Maximum internal inductance L <sub>i</sub>		neglig	jible	
For type WR14-O*-****, TR14-O*-****, WR14-P*-****,	TR14-P*-***	* (cable lengt	th max. 50 r	n)
Maximum internal capacitance	Ci		0.2 nf	
Maximum internal inductance	$L_i$		1 µH/	m

Permissible ambient-/process temperature range in °C depend on Pi

Pi	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

#### 5 Cable sensor type RKW-8-\*-\*\*\*\*, RKW-9-\*-\*\*\*\*

#### Ex ia IIC T1 ... T6 Ga

Maximum input voltage	Ui	DC	30	V
Maximum input current	l₁ °		100	mA
Maximum input power	Pi		see ta	able
(cable length max. 50 m)				
Maximum internal capacitance	Ci		0.2 nl	F/m
Maximum internal inductance	Li		1 µH/	m'

Permissible process temperature in °C depends on P<sub>i</sub> and the temperature class.

For types RKW and sensor diameter 3 mm, 4 mm, 6 mm und 8 mm:

temperature class	20 mW	50 mW	250 mW	500 mW	750 mW
T1	434	425	367	294	221
T2	284	275	217	144	71
Т3	184	175	117	44	1
T4	124	115	57	1	1
T5	89	80	22	1	1
Т6	74	65	7	1	1

Ambient temperature range of the connection cable and plug connector for type RKW-8-\*-\*\*\*\*, RKW-9-\*-\*\*\*\*:

-40 °C bis +75 °C für T5 ... T6 -40 °C bis +100 °C für T1 ... T4

#### Ex ia IIIC T135°C Da

Maximum input voltage Maximum input current	U <sub>I</sub> I <sub>I</sub>	DC	30 100 see ta	V mA
Maximum input power (cable length max. 50m)			0.2 nl	
Maximum internal capacitance Maximum internal inductance	C <sub>i</sub>		1 µH/	





Certificate No.: IECEx BVS 17.0091X

Annex Page 13 of 13

Permissible ambient-/process temperature range in °C depend on Pi

Pi	Ambient-/Process temperature range
750 mW	-40 °C up to +40 °C
650 mW	-40 °C up to +70 °C
550 mW	-40 °C up to +100 °C

#### Specific Conditions of Use:

1 The temperature sensors respectively the measuring inserts respectively the cable sensors are suitable for use within the following ambient temperature range: see ratings

In case that process temperatures measured deviate from these parameters, the ambient temperature range and the temperature class defined, refer only to the connection head or the sleeve, connection cable and plug connector depending on type. The impact of the process temperature on the temperature of the neck tube has to be considered separately in use of the temperature sensors respectively the measuring inserts respectively the cable sensors.

Appropriate measures, e.g. an adequate choice of neck tube length, shall assure that, dependent on type, the temperature of the connection head or the sleeve, connection cable and plug connector is decoupled from the process temperature as such.

- 2 The manufacturer's instructions regarding admissible process conditions shall be adhered to.
- 3 For the measuring inserts type WR14-X-\*\*\*\*-\* and TR14-X-\*\*\*\*-\* valid:

The measuring insert has to be installed into an enclosure that guarantees at least the type of protection IP20.

The internal wiring has to meet the requirements of clause 6.3.12 of EN 60079-11:2012.

The installation has to be carried out in a manner that the air gaps between blank parts of intrinsically safe circuits and metallic enclosure parts are at least 3 mm.

4 For the sensors with marking Ex ia IIC T1 ... T6 Ga/Gb and Ex ia IIIC T135°C Da/Db valid:

The separation wall (stainless steel tube) has a wall thickness ≥ 1 mm.

The installation into a separation wall between areas with Ga/Gb - resp. Da/Db - requirements has to be done in such a way, that all metallic parts are conductively connected to the metal container wall; or, if the container is made of plastic, that all insulated metal parts are connected to equipotential bonding.

The sensors have to be installed into the separation wall with standardized connections. At the place of installation, technical tightness has to be ensured.

5 For the sensors type WR14-O\*-\*\*\*\*, TR14-O\*-\*\*\*\*, WR14-P\*-\*\*\*\*, TR14-P\*-\*\*\*\*, RKW-8-\*-\*\*\*\*, RKW-9-\*-\*\*\*\* valid:

In gas-explosive areas, the sensors have to be installed in such a way, that electrostatic charging is excluded.

6 For the sensors type WR14-O\*-\*\*\*\*, TR14-O\*-\*\*\*\*, WR14-P\*-\*\*\*, TR14-P\*-\*\*\*, WR14-M\*-\*\*\*, TR14-M\*-\*\*\*, RKW-8-\*-\*\*\*\*, RKW-9-\*-\*\*\*\* valid:

The metallic parts of the sensors have to be included into the potential equalization.

7 The intrinsically safe circuit of the sensors with diameter 3 mm and more than 4 internal wires, sensors with diameter < 3 mm and sensors with diameter > 3 mm and more than 6 internal wires has to be regarded as earthed. Along to the intrinsically safe circuit potential equalisation has to be provided.